
Pattonville Fire Protection District

William Esterline, Chairman
Robert Biondo, Secretary
Robert Soutier, Treasurer



Terry E. Loehrer, Fire Chief
Matt LaVanchy, Asst. Chief
Paul Richard, Deputy Chief

SPRINKLER PERMIT REQUIREMENTS

4 or less sprinkler heads:

Repair, alteration, addition and/or relocation of 4 or less sprinkler heads does NOT require a permit or the submission of plans.

5 to 19 sprinkler heads:

A permit is required for the alteration, addition or relocation of 5-19 sprinklers. An application for permit is required, but sealed drawings are not.

20 or more sprinkler heads:

Sealed drawings and a permit application must be submitted and a permit will be issued for the alteration, addition or relocation of 20 or more sprinklers.

Sealed drawings and permit application are required for:

1. Any new system.
2. A change in system type.
3. Increase in Occupancy Hazard Classification.
4. Any modifications to an ESFR or Extended Coverage System.
5. Alteration, addition or relocation of 20 or more sprinklers.

Contact us if you have any questions: 314-281-5026.

Paul Richard
Fire Marshal

Rev. 5/14